



**Community Development Department**  
**Building Safety Division**  
 14177 Frederick Street, Moreno Valley, CA 92552  
 Office 951.413.3350 Fax 951.413.3363

**Eligibility Checklist for Expedited  
 Electric Vehicle Charging Station  
 Multi-Unit Dwelling Permitting**

***This checklist is provided to determine if your application is eligible for expedited EVCS processing.  
 If any item is checked NO, revise design, otherwise application must go through standard review process.***

Type of Charging Station(s) Proposed	Power Levels (proposed circuit rating)	Check one
Level 1	110/120 volt alternating current (VAC) at 15 or 20 Amps	<input type="radio"/>
Level 2 - 3.3 kilowatt (kW) (low)	208/240 VAC at 20 or 30 Amps	<input type="radio"/>
Level 2 – 6.6kW (medium)	208/240 VAC at 40 Amps	<input type="radio"/>
Level 2 – 9.6kW (high)	208/240 VAC at 50 Amps	<input type="radio"/>
Level 2 – 19.2kW (highest)	208/240 VAC at 100 Amps	<input type="radio"/>
DC Fast Charging	440 or 480 VAC	<input type="radio"/>
Other (provide detail)	Provide ratings	<input type="radio"/>

**PERMIT APPLICATION**

A. Is the application complete with the following information: Project address, parcel #, builder/owner name, contractor name, valid contractor license #, phone numbers etc.	<input type="radio"/> Y	<input type="radio"/> N
B. Does the application include EVCS manufacturer's specs and installation guidelines	<input type="radio"/> Y	<input type="radio"/> N

**ELECTRIC LOAD CALCULATION WORKSHEET**

A. Is an electrical load calculation worksheet included (CEC 220)	<input type="radio"/> Y	<input type="radio"/> N
B. Based on the load calculation worksheet, is a new electrical service panel upgrade required	<input type="radio"/> Y	<input type="radio"/> N
1) If yes ,do plans include the electrical service panel upgrade	<input type="radio"/> Y	<input type="radio"/> N
C. Is the charging circuit appropriately sized for a continuous load (125%)	<input type="radio"/> Y	<input type="radio"/> N
D. If charging equipment proposed is a Level 2 - 9.6kW station with a circuit rating of 50 amps or higher, is a completed circuit card with electrical calculations included with the single-line diagram	<input type="radio"/> Y	<input type="radio"/> N

**SITE PLAN & SINGLE LINE DRAWING**

A. Is a site plan and electrical plan with a single-line diagram included with the permit application	<input type="radio"/> Y	<input type="radio"/> N
1) If mechanical ventilation requirements are triggered for indoor venting requirements (CEC 625.29 (D)), is a mechanical plan included with the permit application	<input type="radio"/> Y	<input type="radio"/> N
C. Is the site plan fully dimensioned and drawn to scale	<input type="radio"/> Y	<input type="radio"/> N
1) Showing location, size, and use of all structures	<input type="radio"/> Y	<input type="radio"/> N
2) Showing location of electrical panel to charging system	<input type="radio"/> Y	<input type="radio"/> N
3) Showing type of charging system and mounting	<input type="radio"/> Y	<input type="radio"/> N

**COMPLIANCE WITH 2013 CALIFORNIA ELECTRICAL CODE (TITLE 24, PART 3)**

A. Does the plan include EVCS manufacturer's specs and installation guidelines	<input type="radio"/> Y	<input type="radio"/> N
B. Does the electrical plan identify the amperage and location of existing electrical service panel	<input type="radio"/> Y	<input type="radio"/> N
1) If yes, does the existing panel schedule show room for additional breakers	<input type="radio"/> Y	<input type="radio"/> N
C. Is the charging unit rated more than 60 amps or more than 150V to ground	<input type="radio"/> Y	<input type="radio"/> N
If yes, are disconnecting means provided in a readily accessible location in line of site and within 50' of EVCS. (CEC 625.23)	<input type="radio"/> Y	<input type="radio"/> N
D. Does the charging equipment have a Nationally Recognized Testing Laboratory (NRTL) approved listing mark. (UL 2202/UL 2200)	<input type="radio"/> Y	<input type="radio"/> N
E. If trenching is required, is the trenching detail called out	<input type="radio"/> Y	<input type="radio"/> N

- |  |                         |                         |
|--|-------------------------|-------------------------|
| 1) Is the trenching in compliance with electrical feeder requirements from structure to structure? (CEC 225)                       | <input type="radio"/> Y | <input type="radio"/> N |
| 2) Is the trenching in compliance of minimum cover requirements for wiring methods or circuits (18" for direct burial per CEC 300) | <input type="radio"/> Y | <input type="radio"/> N |

**COMPLIANCE WITH 2013 MANDATORY CALGREEN CODE FOR NEW CONSTRUCTION**

---

- |  |                         |                         |
|--|-------------------------|-------------------------|
| A. Do CAL Green EV Readiness installation requirements apply to this project   | <input type="radio"/> Y | <input type="radio"/> N |
| 1) Should be identified during plan review. (4.106.4.1 & 4.106.4.1.1)  |                         |                         |
| 2) Do the plans demonstrate conformance with mandatory measures for 3% of total parking spaces, but no less than one, for new multifamily dwellings with 17+ units that must be EV capable   | <input type="radio"/> Y | <input type="radio"/> N |
| * <b>2016 CAL Green proposed mandatory requirements</b> for new construction include measures for 5% of total parking spaces, but no less than one, for new multifamily dwellings with 17+ units that must be EV capable (effective January 1, 2017) |                         |                         |